


# Cable Ampacity using the Nehers-McGrath Method

Heat is generated when current flows through a cable. The ampacity of a cable is the amount of current a cable can carry without exceeding its temperature rating. Accurately estimating ampacity is critical to minimizing the total lifetime cost of a cable installation, and minimizing maintenance issues.

Nehers and McGrath (1957) published a steady-state method to compute the temperature rise in cables. This method forms the the basis of the cable ampacity tables in The National Electrical Code (NEC) 2017 and IEEE 399-1997.



This application implements the Nehers-McGrath equations and cross-checks the results against those tabulated in the NEC; the good agreement means that this worksheet can be the basis of more complex cable ampacity calculations.

The NEC gives cable ampacity for a range of standard conductors, cable arrangements and duct configurations, and assumes

- a soil temperature of 20°C at a depth of 36 inches and thermal resistivity of 90 K cm/W
- 100% load factor
- one of several duct configurations
- a burial depth of 36 inches and cable separation of 7.5 inches
- all cables have the same ampacity

This narrow range of conditions are not always applicable. For example, the southern US states often reach a soil temperature of 25°C at a depth of 36 inches, reducing the ampacity by 5% or more. Implementing the Nehers-McGrath method in Maple can assist electrical power systems engineers with modeling non-standard configurations.

This table confirms the results of the application for several standard NEC conductors.

## References

J. H. Neher and M. H. McGrath, "The calculation of the temperature rise and load capability of cable systems, " Power Apparatus and Systems, Transactions of the American Institute of Electrical Engineers, vol.76, no.3, pp.752,764, April 1957.

## Parameters

---

Thermal resistance of the RHH (Rubber High Heat) insulation	$\rho_i := 500 \text{ K}\cdot\text{cm}\cdot\text{W}^{-1}$
Thermal resistance of the soil	$\rho_{\text{soil}} := 90 \text{ K}\cdot\text{cm}\cdot\text{W}^{-1}$
Soil diffusivity factor	$\delta := 0.5 \times 10^{-6} \text{ m}^2\cdot\text{s}^{-1}$
Temperature coefficient of conductor copper: $3.93 \times 10^{-3}$ aluminium: $4.29 \times 10^{-3}$	$\alpha_n := 3.93 \times 10^{-3}$
Electrical resistivity copper: $1.7241 \times 10^{-8} \text{ ohm m}$ aluminium: $2.62 \times 10^{-8} \text{ ohm m}$	$\rho := 1.7241 \times 10^{-8} \text{ ohm}\cdot\text{m}$
Maximum allowable conductor temperature	$T_c := (273.15 + 75) \text{ K}$
Ambient soil temperature	$T_a := (273.15 + 20) \text{ K}$
Burial depth	$L := 36 \text{ inch}$
Axial separation	$d := 7.5 \text{ inch}$
Load factor (fraction of the cable's daily loading)	$I_f := 1$
System frequency	$f := 60 \text{ Hz}$
Skin effect coefficient for this type of conductor	$k_s := 1$
Proximity effect (0 since cables are unsheathed, not touching and axial separation is much greater than cable diameter)	$y_p := 0.0$

## Parameters from National Electric Code 2017

---

Diameter outside of insulation  
NEC Table 5 RHH w/out covering page 684

$$D_i := 1.502 \text{ inch}$$

Diameter over bare conductor  
NEC Table 5A page 688

$$d_c := 1.060 \text{ inch}$$

DC resistance of the uncoated  
conductor at 75°C  
NEC Table 8 page 689

$$R_{dc,75} := 0.0129 \times 10^{-3} \text{ ohm}\cdot\text{ft}^{-1}$$

AC resistance  
NEC Table 9 page 690, PVC conduit

$$R_{ac,75\_NEC} := 0.015 \times 10^{-3} \text{ ohm}\cdot\text{ft}^{-1}$$

Rated ampacity for this problem  
NEC Table B.310.10 page 707.  
The calculated ampacity should closely  
match the NEC value.

$$I_{NEC} := 887 \text{ A}$$

## Conductor

---

Diameter where contact with the  
soil starts

$$D_e := D_i$$

Insulation thickness

$$t_i := 0.5 \cdot (D_i - d_c) = 0.221 \text{ in}$$

Area of the conducting material

$$S := \frac{\pi \cdot d_c^2}{4} = 0.882 \text{ in}^2$$

## Skin Effect

---

Tendency of current density to be concentrated near the conductor surface

Nehers-McGrath

Skin effect factor using Nehers-McGrath

$$F_k := \frac{8 \text{ s}^2 \cdot 2 \cdot \pi \cdot f^2 \cdot 10^{-7}}{R_{dc,75} \cdot 10^6 \text{ ft}\cdot\text{ohm}^{-1}} = 1.40 \times 10^{-3}$$

Skin effect

$$y_s := k_s \cdot F_k = 1.40 \times 10^{-3}$$

AC resistance  $R_{ac_{75}} := R_{dc_{75}} \cdot (1 + y_s + y_p) = 1.292 \times 10^{-5} \frac{\Omega}{ft}$

Full skin effect needed in rating equation  $Y_c := y_s + y_p = 1.40 \times 10^{-3}$

Anders

DC resistance at 75C with 2% laying factor  $R_{prime} := \frac{1.02 \cdot \rho}{S} \cdot \left( 1 + \frac{\alpha_n}{K} \cdot (T_c - T_a) \right) = 1.14 \times 10^{-5} \frac{\Omega}{ft}$

Skin effect factors  $F_{k2} := \frac{8 s^2 \cdot 2 \cdot \pi \cdot f^2 \cdot 10^{-7}}{R_{prime} \cdot 10^6 ft \cdot ohm^{-1}} = 1.58 \times 10^{-3}$

$$x_s := F_{k2} \cdot k_s = 0.002$$

$$y_s := \frac{x_s^2}{192 + 0.8 \cdot x_s^2} = 1.301 \times 10^{-8}$$

AC resistance  $R_{ac_{75}} := R_{prime} \cdot (1 + y_s + y_p) = 1.14 \times 10^{-5} \frac{\Omega}{ft}$

Full skin effect needed in the rating equation  $Y_c := y_s + y_p = 1.301 \times 10^{-8}$

## Thermal Resistance of Insulation

---

Nehers-McGrath equation 44  $R_i := 0.012 \frac{ft}{cm} \cdot \rho_i \cdot \log_{10} \left( \frac{D_i}{d_c} \right) = 0.908 \frac{ft \cdot K}{W}$

Anders  $T_1 := \frac{\rho_i}{2 \cdot \pi} \cdot \ln \left( 1 + 2 \cdot \frac{t_i}{d_c} \right) = 27.735 \frac{K \cdot cm}{W}$

## Thermal Resistance External to Cable

---

Loss factor where an allowance is made for cyclical loading  $LF := 0.3 \cdot lf + 0.7 \cdot lf^2 = 1.000$

Fictitious diameter at which the effect of the loss factor commences (Nehers-McGrath equation 45)  $D_x := 1.02 \cdot \sqrt{\delta \cdot 24 \text{ hour}} = 0.212 \text{ m}$

Mutual heating effect of other cables from Kenelly  $F := \left( \frac{\sqrt{(2 \cdot L)^2 + d^2}}{d} \right)^2 = 93.160$

External thermal resistivity for direct buried cables

$$T_{\mu 4} := \frac{\rho_{\text{soil}}}{2 \cdot \pi} \cdot \left( \ln \left( \frac{D_x}{D_e} \right) + l_f \cdot \ln \left( \frac{4 \cdot L \cdot F}{D_x} \right) \right) = 4.275 \frac{\text{ft K}}{\text{W}}$$

## Total Thermal Resistivity

---

Effective total resistivity, including the effects of the conductor, soil, sheath and conduit (where applicable)

$$R_{\text{ca}} := T_1 + T_{\mu 4} = 5.185 \frac{\text{ft K}}{\text{W}}$$

As a check, this is the total resistivity calculated from the ampacity given in the NEC

$$R_{\text{ca\_NEC}} := \frac{T_c - T_a}{R_{\text{dc},75} \cdot I_{\text{NEC}}^2} = 5.419 \frac{\text{ft K}}{\text{W}}$$

## Maximum Allowable Current

---

Calculated current

$$I_{\text{calc}} := \sqrt{\frac{T_c - T_a}{R_{\text{dc},75} \cdot (1 + Y_c) \cdot R_{\text{ca}}}} = 906.15 \text{ A}$$

Percentage error to NEC tabulated value

$$\frac{I_{\text{calc}} - I_{\text{NEC}}}{I_{\text{NEC}}} \cdot 100 = 2.159$$